


**OFFICE OF ASSISTANT ENGINEER,
P.H. SUB DIVISION,HAJIPUR.**

Lt. No. 775 /Hajipur

Date:- 17/07/2025

TO WHOM IT MAY CONCERN

This is to certify that Sharda Vidyapeeth at Mishri Mahal, Baranti, Bidupur R.S., Vaishali Bihar on the basis of inspection and Water Test Report (Attached) vide Lt. No. 38 Dt 10.07.2025 of Chemist PHED Divisional Lab Hajipur, has safe drinking water facilities for the students and members of staff of the Institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State Govt. This above is valid for a period of one Year.


17/7/25
JE Bidupur


Assistant Engineer
P. H. Sub-Division, Hajipur

Letter No: 38

Date: 10-07-25

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

S.L. No.	Block	Panchayat	Village	Name of habitation	Location of source	Latitude		Longitude		pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	AL	Fe	NO ₃	SO ₄	F	As	Total Coli	Report number for verification	Remarks		
						N	E	E	S																			
																											Min.	Sec.
1	Bidupur	Bidupur	Bidupur	Bidupur	Sharda Vidyapeeth Bidupur, R.S.					7.46	1.26	244	159	88	28	3	16	98						0.15		5.01	-18	
Permissible Limit* in absence of alternative source						68.8	1.8	100	200	75	30	250	200	0.3	40	200	0.1	5.01										
Limit						100	3.0	2000	600	200	100	1000	500	1.0	100	400	1.5	90										

* (1) Drinking Water Specification Second Revision: IS: 10500:2012. (2) BDL means Below Detection Limit. (3) N/A means no relation.
(4) Throughout any year, 95% of the samples should not contain coliform organisms in 100ml, (5) No sample should contain more than 10 coliform organisms per 100ml. (6) Coliform organisms should not be detected in 100ml of any two consecutive samples.

Chemist
PH Division Hajipur
10-07-25